

SUBMITTAL DRAWING

JOB NAME: _____
 LOCATION: _____
 ARCHITECT: _____
 ENGINEER: _____
 CONTRACTOR: _____

Type B Gas Vent


PIPE SECTION

3"-30" DIAMETER

DATE: 05/03/05

SUBMITTED BY: _____

DRAWING #: B1-4



PART NO.	A O.D.	B I.D.	ASSEMBLED LENGTH C						
			5"	11"	17"	23"	35"	47"	59"
3E	3-1/2"	3"	5"	11"	17"	23"	35"	47"	59"
4E	4-1/2"	4"	5"	11"	17"	23"	35"	47"	59"
5E	5-1/2"	5"	5"	11"	17"	23"	35"	47"	59"
6E	6-1/2"	6"	5"	11"	17"	23"	35"	47"	59"
7R	8"	7"	5"	11"	17"	23"	35"	47"	59"
8R	9"	8"	5"	11"	17"	23"	35"	N/A	59"
9R	10"	9"	5"	11"	17"	23"	35"	N/A	N/A
10R	11"	10"	5"	11"	17"	23"	35"	N/A	N/A
12R	13"	12"	5"	11"	17"	23"	35"	N/A	N/A
14R	15"	14"	5"	11"	17"	23"	35"	N/A	N/A
16R	17"	16"	5"	11"	17"	23"	35"	N/A	N/A
18R	19"	18"	5"	11"	17"	23"	35"	N/A	N/A
20R	21"	20"	5"	11"	17"	23"	35"	N/A	N/A
22R	23"	22"	5"	11"	17"	23"	35"	N/A	N/A
24R	25"	24"	5"	11"	17"	23"	35"	N/A	N/A
26R	27"	26"	5"	11"	17"	23"	35"	N/A	N/A
28R	29"	28"	5"	11"	17"	23"	35"	N/A	N/A
30R	31"	30"	5"	11"	17"	23"	35"	N/A	N/A
LISTED LENGTH D			6"	12"	18"	24"	36"	48"	60"

• **MATERIAL:**
 OUTER – MIN. 0.018 THICK, GALVANIZED STEEL
 INNER – 0.012 THICK ALUMINUM ALLOY